

## Form A2-16 Form of Tender Clarifications

Contract for Engineering, Procurement, and Construction of <b>170 MW<sub>AC</sub></b> PV Power Plant <b>Project</b>	TENDER DOCUMENTS	Clarification List No.1	Date: 29/06/2022
---	------------------	-------------------------	------------------

Item no.	Volume	Section	Chapter	Page	Question	Answer
1	RFP	7.3	7	35	<p>The GECOL specification was not received with Tender document like:</p> <ul style="list-style-type: none"> <li>• MV ring voltage.</li> <li>• Power distribution system – MV ring.</li> <li>• Low voltage transformer.</li> <li>• LV AC power and control cables.</li> <li>• 11 kV XLPE cables.</li> <li>• Medium voltage protection.</li> <li>• Grounding and lightning protection system</li> </ul>	<p>GECOL specification</p> <p>Visit REAOL website <a href="http://www.reaol.ly">www.reaol.ly</a></p>
2	RFP	7.3.11	7	37 to 37	The Libyan Grid Code was not received with tender documents	<p>Grid Code</p> <p>Visit REAOL website <a href="http://www.reaol.ly">www.reaol.ly</a></p>
3				38	As you mentioned in your RFP that you request to use a central inverter 'but as we are a Huawei Supplier we want to take approval from your side to use a string inverter .	Yes, you can use a string inverter, but the technical and economic benefits of this proposal should be clarified.
4	RFP	3.2	3	7	As you mentioned in your RFP, please provide us the location site for the projects.	It is already defined

5	RFP				What's the certain criteria used at evaluation of the tenderer (Evaluation Criteria)?	It is internal process
---	-----	--	--	--	---	------------------------